


Connecticut Precast Corp.


555 Fan Hill Road, Monroe, CT 06468 Telephone (203) 268-8688

Fax (203) 452-1007

Distribution Boxes



DB-8 (7 Outlets)



NOTES:

1. Minimum Concrete Compressive Strength: 4,000 PSI @ 28 Days.
2. Equipped with Polypropylene pipe seals.
3. Reinforced with #3 bars.