

Connecticut Precast Corp.



555 Fan Hill Road, Monroe, CT 06468

Telephone (203) 268-8688

Fax (203) 452-1007

Utilities

Northeast Utilities
Round Concrete Handhole
36" Diameter x 36" High
Item # SPC H-020



NOTES:

1. Minimum Concrete Compressive Strength: 5,000 PSI @ 28 Days.
2. Steel reinforced with 3"x6"-W2.9 X W2.9 wire mesh.
3. Contractor shall conform to Northeast Utilities standard specifications.