

Connecticut Precast Corp.


555 Fan Hill Road, Monroe, CT 06468

Telephone (203) 268-8688

Fax (203) 452-1007

Oil Separators

1000 Gallon Capacity
Grease & Oil
Pre-Treatment Tank
H₂O Loading Design



NOTES:

1. Minimum Concrete Compressive Strength: 4,000 PSI @ 28 Days.
2. Design Loading: AASHTO HS-20.
3. Meets or exceed local standards.
4. All shiplap joints sealed with Butyl Rubber.
5. Monolithic Design.
6. D.O.T. and D.E.P. approved.
7. Tees provided and installed by others.
8. Epoxy coated interior and asphalt coated exterior.