




Utilities

Northeast Utilities
Transformer Pad
Residential
Item # P-009



NOTES:

1. Minimum Concrete Compressive Strength: 5,000 PSI @ 28 Days.
2. To be used with SPC H-020 Round Handhole.
3. Contractor shall conform to Northeast Utilities standard specifications.